

CERTIFICATE

Certificate No.: PL 24105880 002

Project No.: 89212247

Holder: Abriso nv
Gijzelbrechtegemstraat 8 – 10
8570 Anzegem
Belgium

Product : **Underlayment: SPEMI HDR**
Total thickness : 1.7 mm
Total mass : 290 gr/m²

Certified in combination with : Floorcovering: 8 mm click laminate.

On basis of the results of the tests specified below, we declare that the above specimen fulfils the requirements of the TÜV Rheinland Testmark **Noise Reduction** including **Regular Product Surveillance**. TÜV Testmark and Underlayments, Test Protocol Impact Sound – 2017 EV


NB: This certificate itself shall not be considered as a type examination certificate.

Performance properties	Requirement	Result
Impact sound improvement according ISO 10140 and ISO 717-2	≥ 10 dB ΔL_{lin}	Pass

Full details of the results can be found in the following report(s):

Reference	Date of issue	Result
Initial test report: AC 5951	04-2014	10 dB ΔL_{lin} & 21 dB ΔL_w

Arnhem, 09-10-2017



R. de Jonge, Managing director
Page 1 of 1